

SCE Aircraft Operations Flight Request Form

Instructions: Please complete this form in its entirety and email to: airops@sce.com or fax to 909-974-4678. Once this form is received by Aircraft Operations, you will receive a response within 24 hours. For questions call SCE Aircraft Operations Dispatch at PAX 11676.

Requestor Information

Flight requested by:*	
Department:*	
Pax:*	
Cell Number:*	
Email Address:*	

SAP Accounting Number*	
-------------------------------	--

Flight Description

Please choose a mission type:

- | | | |
|---|--------------------------------------|---|
| ☐ Camera – HD/IR | ☐ Line String | ☐ Pole-set |
| ☐ Crew support | ☐ Passenger | ☐ Recon |
| ☐ External Load | ☐ Patrol | ☐ Training |
| ☐ HEC | ☐ Photo | ☐ Need more info, please contact |

Mission specific details (ex: Passenger name, pole size/weight, external load type, etc):

General Operating Location	
District	
LZ Coordinates (if known)	
Pick-up location for passenger flights	
Drop-off location for passenger flights	

Date(s) for which service is requested	
Time of Pick-up	
Approx. mission duration (if known)	
Back-up date for mission (if known)	

Authorizer	
Authorizer PAX and cell number	

**required information*

For office use only

Date Received by Aircraft Operations: _____ Date Initial Contact Made: _____

Referred to contractor: ☐ No ☐ Yes, Date: _____ Company: _____

Follow up status: ☐ Week 1 _____

☐ Week 2 _____

☐ Week 3 _____

TD 1499629 CACHUMA 16KV VEGAS

SKETCH SHEET

PROJECT REQUIREMENTS (Y/N)

EDISON EASEMENT REQUIRED	☐
PWRD 88 REQUIRED	☐
PERMIT REQUIRED	☒
PERMIT TYPE: <u>TRAFFIC</u>	
OUTAGE REQUIRED	☐
OUTAGE DATE: _____ Time: _____	
TRAFFIC CONTROL REQUIRED	☒
PED. TRAFFIC CONTROL REQ'D	☐
CONVEYANCE LETTER REQ'D	☐
ENVIRONMENTAL CLEARANCE REQ'D	☒
CSD 140 (TLM) REQ'D	☐

1882436E
40

1523069E
30

RM: 1413683E

RM: DF 50' CL 4
RM: 10' DBL XARM
RM: 6 - 16 KV PINS
RM: 9/32 DOWN GUY

1413683E
50
25/16
3366563798

RM: GROUND (SEC)

TR: BX 25/14 ON POT

IN: 1413683E

IN: DF-TB 50' CL 2 - (HARD SET 2' NORTH OF EX POLE)

IN: 10' DBL COMP XARM

IN: 6 - 16 KV PINS (POLYMER)

IN: 9/32 DOWN GUY

IN: 2 - CUTOUTS & BLFS

IN: GROUND (SEC)


TR: BX 25/16 ON POT

Notes:

- NO TRUCK ACCESS
- POSSIBLE CRANE SET FROM SIDE OF ROAD (LANE CLOSURE REQUIRED)
- RE-SET EXISTING TRANSFORMER TO NEW POLE
- INSTALL NEW CUTOUTS AND BLFS
- REPLACE SEC GROUND
- REPLACE 9/32 DOWN GUY
- HARD SET NEW POLE 2' N/O EX POLE

NOT TO SCALE

INSPECTED BY _____
DATE INSPECTED _____



CIRCUIT:

PLANNER
John Hutcheson

JOB NAME

OCI - POLE REPLACEMENT

SUBSTATION:

FOREMAN

STA #:

DISTRICT
49-Santa Barbara

DWO

TD1499629

JOB LOCATION

NEW SAN MARCOS PASS RD 1' W 350' N/O E/CAMINO FIELD

TRUCK

P/E

DATE SENT TO R/W

DIST SKETCH

A.I. NO.

TLM-CSD 140 REQUIRED

YES NO X

T.L.M. DATA:

SIZE KVA CUST %LOAD

DRAWN BY

J. Hutcheson

26-51C

WORKED BY

INV MAP
NO.'S

J.P.A. NO.

GRID NO.

T.G. PAGE



Google Maps 5100 CA-154

 $34^{\circ} 30' 47.36'' - 119^{\circ} 49' 29.49''$ 

Image capture: Jun 2016 © 2019 Google

Santa Barbara, California



Street View - Jun 2016