

SCE Aircraft Operations Flight Request Form

Instructions: Please complete this form in its entirety and email to: airops@sce.com or fax to 909-974-4678. Once this form is received by Aircraft Operations, you will receive a response within 24 hours. For questions call SCE Aircraft Operations Dispatch at PAX 11676.

Requestor Information

Flight requested by:*	
Department:*	
Pax:*	
Cell Number:*	
Email Address:*	

SAP Accounting Number*	
-------------------------------	--

Flight Description

Please choose a mission type:

- | | | |
|---|--------------------------------------|---|
| ☐ Camera – HD/IR | ☐ Line String | ☐ Pole-set |
| ☐ Crew support | ☐ Passenger | ☐ Recon |
| ☐ External Load | ☐ Patrol | ☐ Training |
| ☐ HEC | ☐ Photo | ☐ Need more info, please contact |

Mission specific details (ex: Passenger name, pole size/weight, external load type, etc):

General Operating Location	
District	
LZ Coordinates (if known)	
Pick-up location for passenger flights	
Drop-off location for passenger flights	

Date(s) for which service is requested	
Time of Pick-up	
Approx. mission duration (if known)	
Back-up date for mission (if known)	

Authorizer	
Authorizer PAX and cell number	

**required information*

For office use only

Date Received by Aircraft Operations: _____ Date Initial Contact Made: _____

Referred to contractor: ☐ No ☐ Yes, Date: _____ Company: _____

Follow up status: ☐ Week 1 _____


☐ Week 2 _____

☐ Week 3 _____

LOCATION DETAIL

TD 1556869

HURST 16KV SAN MARCOS



RM: 1453466E

RM: 40' DF CL 4

RM: 1 - 10' X-ARM

RM: 2 - 16 KV DE. INS.

RM: 2 - FUSES & HOLDERS

RM: 1 - 15KVA XFMR

S/N:

RM: 1 - 166 ROLLER

TR: SPAN GUY

IN: 1453466E

IN: 40' COMP CL 2

IN: 1 - 10' COMP X-ARM

IN: 2 - 16 KV DE. INS.

IN: 2 - ELF FUSES WITH CONTACTS

IN: 1 - 25KVA XFMR

S/N:

IN: 1 - 166 ROLLER

IN: GROUND WIRE FOR XFMR

PROJECT REQUIREMENTS (Y/N)

EDISON EASEMENT REQUIRED ☒

PWRD 88 REQUIRED ☒

UG CIVIL ONLY WORK ORDER ☒

PERMIT REQUIRED ☒

PERMIT TYPE: ---

OUTAGE REQUIRED ☒

OUTAGE DATE: TRD TIME: ---

TRAFFIC CONTROL REQUIRED ☒

PED. TRAFFIC CONTROL REQ'D ☒

CONVEYANCE LETTER REQ'D ☒

ENVIRONMENTAL CLEARANCE REQ'D ☒

CSD 140 (TLM) REQ'D ☒

T.L.M. DATA:

	SIZE	KVA	CUST	% LOAD
EXIST.	15KVA	18	5	122 %
PROP.	25	18	5	72 %

VOLTAGE DROP: ---

FLICKER FACTOR: ---

PRI. CIRCUIT: ---

NOTES:

- NO TRUCK ACCESS
- TRANSFER EXISTING CONDUCTORS TO NEW POLE
- TRANSFER EXISTING COMM TO NEW POLE
- TRANSFER SPAN GUY TO NEW POLE



SOUTHERN CALIFORNIA
EDISON
AN EDISON INTERNATIONAL COMPANY

NOT TO SCALE

DISTRICT <u>SB/49</u>		PROJ. MGR. PHONE		PLANNER PHONE		DESIGNER	
PROJECT NO.	SERVICE REQUEST	MSR NO.	PRODUCT-1 <u>1556869</u>		ASSOC DESIGN		
CIRCUIT / VOLTAGE		THOMAS GUIDE	PRODUCT-2		ASSOC DESIGN		
SUB / PG NO.		CIRCUIT CODE	PRODUCT-3		ASSOC DESIGN		
INVENTORY MAP		J.P.A. NO.		PROPOSED CONSTRUCTION (LOCATION)			
				<u>CAMINO DEL RIO R/O P/P 195'S. 105' N/O</u>			
				<u>LINE TRAIL</u>			
TYPE	DATE	APPROVED BY	CHECKED BY	DRAWN BY	PAX #	SHEET <u>1</u> OF <u>1</u>	DESIGN\DRWG NO.
Southern California Edison Company							

