

10-1-19 Due Date

* NOTES:
HIGH FIRE - TIER 2
EAGLE ZONE
ENVIRO POLE - OPEN SPACE
FEDERAL LAND - BUREAU OF LAND MANAGEMENT
BULLETIN 322 AREA
E-ALL POLE
COMPOSITE POLE
RIGHTS CHECK REQ'D - FEDERAL LAND
TR: 3/C-336A-33KV @ 42'

NTO
USA marked
No T.C.
Helicopter set
Primary outage to 33KV & 12KV

HFIA
TIER: 2
SECTIONAL COMPOSITE
POLE(S) INSTALLED
ON THIS WORK ORDER

ENVIRONMENTAL PACKAGE
MONITOR ☐
TRAINING ☐
NESTING/EAGLE ZONE ☐
PRE-CON SURVEY (ALLOW 2 WEEKS) ☒

9

RM

4698472E

50'

Class C4

RM: 1- POLE 50' CLASS 4 WOOD FULL TREAT

RM: 1- XA SNGL VB 10' STEEL PINS

RM: 1- INS POLY & PIN 33KV CLMP #4-336 ACSR

RM: 2- 33KV SUSPENSION INSULATOR

RM: 2- CLAMP FOR SUSPENSION INSULATOR

10

SET 1' SOUTHEAST
POLE

4698472E

50'

Class C1

IN: 1- POLE 50' CLASS 1 RS COMP SEC POLE

IN: 1- XA SNGL TAN HD COMP 10' W/BKT

IN: 1- INS POLY W/PIN 33KV CLMP #4-653 ACSR


IN: 2- 33KV SUSPENSION INSULATOR

IN: 2- CLAMP FOR SUSPENSION INSULATOR


N: 34° 1' 9.77"

W: 116° 37' 20.11"

ELEVATION: 2622'



10/5/19




PROJECT REQUIREMENTS (Y/N)	
EDISON EASEMENT REQUIRED	☐
PWRD 88 REQUIRED	☐
UG CIVIL ONLY WORK ORDER	☐
PERMIT REQUIRED	☒
PERMIT TYPE:	
OUTAGE REQUIRED	☒
OUTAGE DATE:	TIME:
TRAFFIC CONTROL REQUIRED	☐
PED. TRAFFIC CONTROL REQ'D	☐
CONVEYANCE LETTER REQ'D	☐
ENVIRONMENTAL CLEARANCE REQ'D	☒
CSD 140 (TLM) REQ'D	☐

DISTRICT 79 - PALM SPRINGS		PROJ. MGR. SANDOVAL, SANDRA PHONE (909) 660-1362		PLANNER HAMPTON TEDDER PHONE (909) 628-1253		DESIGNER HAMPTON TEDDER	
PROJECT NO. 1636495	SERVICE REQUEST 2544398	MSR NO.	PRODUCT-1 1432973-INFRA REPLAC - DET POLE REPLACEMENT		ASSOC DESGN		
CIRCUIT / VOLTAGE COACHELLA 33KV		THOMAS GUIDE		PRODUCT-2		ASSOC DESGN	
SUB / PG NO. GARNET SUB		CIRCUIT CODE 03715		PRODUCT-3		ASSOC DESGN	
INVENTORY MAP 672-1884-2		J.P.A. NO.		PROPOSED CONSTRUCTION (LOCATION) 4698472E N/O MISSION CREEK RD 82 MI., 2.20 MI W/O HWY 62 PAINTED HILLS, CA			
DATE 2/28/2019	APPROVED BY	CHECKED BY	DRAWN BY SO/HTE	PAX #	SHEET 1 OF 1		
Southern California Edison Company					DESIGN\DRWG NO. 1060967 0 01		



* NOTES:
HIGH FIRE - TIER 2
EAGLE ZONE
ENVIRO POLE - OPEN SPACE
FEDERAL LAND - BUREAU OF LAND MANAGEMENT
BULLETIN 322 AREA
E-ALL POLE
COMPOSITE POLE
RIGHTS CHECK REQ'D - FEDERAL LAND
TR: 3/C-336A-33KV @ 42'

COMPOSITE



7 **RM** **4698473E**
50' Class C4
RM: 1- POLE 50' CLASS 4 WOOD FULL TREAT
RM: 1- XA SNGL VB 10' STEEL PINS
RM: 1- INS POLY & PIN 33KV CLMP #4-336 ACSR
RM: 2- 33KV SUSPENSION INSULATOR
RM: 2- CLAMP FOR SUPENSION INSULATOR

N: 34°1'14.36"
W: 116°37'12.63"
ELEVATION: 2667'

SET 1' NORTHEAST


8 **POLE** **4698473E**
50' Class C1
IN: 1- POLE 50' CLASS 1 RS COMP SEC POLE
IN: 1- XA SNGL TAN HD COMP 10' W/BKT
IN: 1- INS POLY W/PIN 33KV CLMP #4-653 ACSR
IN: 2- 33KV SUSPENSION INSULATOR
IN: 2- CLAMP FOR SUPENSION INSULATOR

PROJECT REQUIREMENTS (Y/N)

EDISON EASEMENT REQUIRED	☐
PWRD 88 REQUIRED	☐
UG CIVIL ONLY WORK ORDER	☐
PERMIT REQUIRED	☒
PERMIT TYPE:	
OUTAGE REQUIRED	☐
OUTAGE DATE: TIME:	
TRAFFIC CONTROL REQUIRED	☐
PED. TRAFFIC CONTROL REQ'D	☐
CONVEYANCE LETTER REQ'D	☐
ENVIRONMENTAL CLEARANCE REQ'D	☒
CSD 140 (TLM) REQ'D	☐

HFIA
TIER: 2

ENVIRONMENTAL PACKAGING
MONITOR
TRAINING
NESTING/EAGLE ZONE
PRE-CON SURVEY (ALLOW 2 WEEKS)



10/6/19



DISTRICT 79 - PALM SPRINGS	PROJ. MGR. SANDOVAL, SANDRA PHONE 909-660-1362	PLANNER HAMPTON TEDDER PHONE 909-628-1253	DESIGNER HAMPTON TEDDER
PROJECT NO. 1636473	SERVICE REQUEST 2544376	MSR NO.	PRODUCT-1 1432958-INFRA REPLAC - DET POLE REPLACEMENT
CIRCUIT / VOLTAGE COACHELLA 33KV	THOMAS GUIDE	PRODUCT-2	ASSOC DESGN
SUB / PG NO. GARNET SUB	CIRCUIT CODE 03715	PRODUCT-3	ASSOC DESGN
INVENTORY MAP 672-1884-2	J.P.A. NO.	PROPOSED CONSTRUCTION (LOCATION) 4698473E MISSION CREEK RD 1.24 MI N, 2 MI W/O HWY 62 PAINTED HILLS, CA	
DATE 2/28/19	APPROVED BY	CHECKED BY	DRAWN BY
TYPE	PAX #	SHEET 1 of 1	
Southern California Edison Company			DESIGN\DRWG NO. 1060952_0.01

* NOTES:
HIGH FIRE - TIER 2
EAGLE ZONE
ENVIRO POLE - OPEN SPACE
FEDERAL LAND - BUREAU OF LAND MANAGEMENT
BULLETIN 322 AREA
E-ALL POLE
COMPOSITE POLE
RIGHTS CHECK REQ'D - FEDERAL LAND
TR: 2/C 2A-12KV @ 37'6"

COMPOSITE

9

RM

332246S

50'
RM: 1- POLE 50' CLASS 4 WOOD FULL TREAT
RM: 1- XA SNGL FB 10' STEEL PINS
RM: 2- INS PORC & PIN 12KV
RM: 1- AUTOMATED SPLICE (#2A)

Class C4

10

SET 1' EAST
POLE

4923856E


45'
IN: 1- POLE 45' CLASS 1 RS COMP SEC POLE
IN: 1- XA SNGL DE HD COMP 10' W/BKT
IN: 2- INS POLY DE 12KV HOT SHOE CNTM #4 & 1/0

Class C1

N: 34°0'16.18"

W: 116°35'55.98"

ELEVATION: 1965'



PROJECT REQUIREMENTS (Y/N)	
EDISON EASEMENT REQUIRED	☐
PWRD 88 REQUIRED	☐
UG CIVIL ONLY WORK ORDER	☐
PERMIT REQUIRED	☒
PERMIT TYPE:	
OUTAGE REQUIRED	☐
OUTAGE DATE: _____ TIME: _____	
TRAFFIC CONTROL REQUIRED	☐
PED. TRAFFIC CONTROL REQ'D	☐
CONVEYANCE LETTER REQ'D	☐
ENVIRONMENTAL CLEARANCE REQ'D	☒
CSD 140 (TLM) REQ'D	☐


D124: Rev. 02/08/18

ENVIRONMENTAL PACKAGE

MONITOR	☐
TRAINING	☐
NESTING/EAGLE ZONE	☐
PRE-CON SURVEY (ALLOW 2 WEEKS)	☒

COMPOSITE

HFIA
TIER: 2



USA

10/6/19



NOT TO SCALE

DISTRICT 79 - PALM SPRINGS		PROJ. MGR. SANDOVAL, SANDRA PHONE 909-660-1362		PLANNER HAMPTON TEDDER PHONE 909-628-1253		DESIGNER HAMPTON TEDDER	
PROJECT NO. 1636473	SERVICE REQUEST 2544376	MSR NO.	PRODUCT-1 1432958-INFRA REPLAC - DET POLE REPLACEMENT		ASSOC DESGN		
CIRCUIT / VOLTAGE SKYBORNE 12KV		THOMAS GUIDE	PRODUCT-2		ASSOC DESGN		
SUB / PG NO. SKYBORNE P.T. SUB		CIRCUIT CODE 16473	PRODUCT-3		ASSOC DESGN		
INVENTORY MAP 668-1890-2		J.P.A. NO.		PROPOSED CONSTRUCTION (LOCATION) 332246S / 4923856E KOLBE RD 1300' SW, 1.29 MI. W/O HWY 62 PAINTED HILLS, CA			
TYPE	DATE	APPROVED BY	CHECKED BY	DRAWN BY	PAX #	SHEET 1 OF 1	DESIGN\DRWG NO. 1060952_0.01

Southern California Edison Company