

E. VALLEY ROAD

GLEN OAKS DRIVE

- NO FTL OR TRAFFIC CONTROL REQUIRED
- HAND DIG
- BULLETIN 322
- IN BACKYARD OF 1746 GLEN OAKS DRIVE
- Joint pole

685:34°26'16.41"
-119°37'5.81"

① RM: 949659E
40' CL 5 (1953)

RM: 1- 40' CLASS 5 POLE ~ 204H103
2- OPEN CUTOUT (1 ONLY) ~ K060118
1- 10' SNGL XARM FB ~ 20XA331
2- DE POLY INS #6 SGL CU ~ 20DI301
1- OH GROUND SECONDARY ~ 20H6004

TR: 202' BARE LOPPER SOLID ~ 20HL 702
1- SD KVA 120/240P ~ VOTS 006
SN

1- RISER 3" TO 2" ~ EUGR007

SET POLE SAME HOLE

② IN: 949659E
95 CL 2 COMP. POLE

IN: 1- POLE 45' LL 1 CMP SEC POLE W 18' SHIELD ~ P-45-C2-CMP-7
2- ELF CUTOFF (1 ONLY) ~ WOOD DB3
2- FE FUSE ELF 15KV SDA ~ FE-ELF-15-SDA-1
1- 10' DBLE DE COMP XARM W/ BRKT ~ XA-DE-CMP-10-DB-1
2- DE POLY ZNS 46 SOL CUM 30DI 301
1- COMP OH GROUND SECONDARY ~ GR-O-SEC-2

SPEED
LIMIT
15
MPH

GLEN OAKS DRIVE

1746



SOUTHERN CALIFORNIA
EDISON
An EDISON INTERNATIONAL Company

NOT TO SCALE

TLM DATA:				
	<u>SIZE</u>	<u>KVA</u>	<u>LUST</u>	<u>%LOAD</u>
EX	50	32	4	64%
PROP	50	32	4	64%

PROJECT REQUIREMENTS (Y/N)

EDISON EASEMENT REQUIRED ☒

PHWD 88 REQUIRED ☒

UG CIVIL ONLY WORK ORDER ☒

PERMIT REQUIRED ☒

PERMIT TYPE: _____ ☒

OUTAGE REQUIRED ☒

OUTAGE DATE: _____ TIME: _____

TRAFFIC CONTROL REQUIRED ☒

FED. TRAFFIC CONTROL REQ'D ☒

CONVEYANCE LETTER REQ'D ☒

ENVIRONMENTAL CLEARANCE REQ'D ☒

CSD 140 (TLM) REQ'D ☒

DISTRICT 49-Santa Barbara		PROJ. MGR. PHONE		PLANNER PHONE		DESIGNER	
PROJECT NO.		SERVICE REQUEST		MSR NO.		PRODUCT-1 ID 1534563	
CIRCUIT / VOLTAGE VALLEY TO 16KV		THOMAS GUIDE		PRODUCT-2		ASSOC DESGN	
SUB / PG NO. CARPINTERIA SUB (LT)		CIRCUIT CODE		PRODUCT-3		ASSOC DESGN	
INVENTORY MAP 17-62C		J.P.A. NO.		PROPOSED CONSTRUCTION (LOCATION) BUENA VISTA RD W/L EX P/T 665' W 612' S/D E VALLEY RD			
TYPE		DATE		APPROVED BY		CHECKED BY	
DRAWN BY		PAX #		SHEET		DESIGN/DRWG NO. 1769266	
Southern California Edison Company							