

SECTIONAL COMPOSITE
POLE(S) INSTALLED
ON THIS WORK ORDER

**** EOI - HI-LINE 12KV ****
NOTIF # 409925244 DUE 8/22/19
STR# 1492567E

REPLACE DET POLE PER NOTIF 409925244
HARDSET POLE 2' EAST IN DIRT
TRANSFER PRIMARIES

SECTIONAL COMPOSITE
POLE(S) INSTALLED
ON THIS WORK ORDER

PROJECT REQUIREMENTS (Y/N)

EDISON EASEMENT REQUIRED ☒
PWRD 88 REQUIRED ☒
UG CIVL ONLY WORK ORDER ☒
PERMIT REQUIRED ☒
PERMIT TYPE: N/A
OUTAGE REQUIRED ☒
OUTAGE DATE: N/A TIME: N/A
TRAFFIC CONTROL REQUIRED ☒
PED. TRAFFIC CONTROL REQ'D ☒
CONVEYANCE LETTER REQ'D ☒
ENVIRONMENTAL CLEARANCE REQ'D ☒
CSD 140 (TLM) REQ'D ☒

D124: Rev. 02/08/18

DISTRICT 33 - HUNTINGTON BEACH		PROJ. MGR. N/A		PLANNER AZAULA, JEFFREY J		DESIGNER DOMINGUEZ, MARVI	
PROJECT NO.	SERVICE REQUEST	MSR NO.	N/A	PHONE	714-895-0573		ASSOC DESIGN 1136005
1756456	2661532	N/A					
CIRCUIT / VOLTAGE	THOMAS GUIDE	PRODUCT-1	1528925-OCI				ASSOC DESIGN N/A
HI LINE 12KV	--	PRODUCT-2	N/A				ASSOC DESIGN N/A
SUB / PG NO.	CIRCUIT CODE	PRODUCT-3	N/A				ASSOC DESIGN N/A
PEBBLY BEACH / H10	08427	N/A					
INVENTORY MAP 868-4191-1		J.P.A. NO.	N/A	PROPOSED CONSTRUCTION (LOCATION)			
				TD1528925 - OCI / EOI			
				ELEVATION 838 N-430,073.84 STA 31 & 15.			
				AVALON, CA 90704			
F	4/18/19	REV/ECW	JJA	WLD	54573	SHEET 1 of 1	DESIGN\DRWG NO. 1136005_0.01
TYPE	DATE	APPROVED BY	CHECKED BY	DRAWN BY	PAX #		
Southern California Edison Company							



SCALE: 1" = 100'



HARD SET 2' EAST

POLE

1492567E

70'

Class C1

IN: 1- POLE 70' CLASS 1 RS COMPOSITE SECTIONAL
IN: 3- XA SNGL TAN HD COMP 10' W/BKT
IN: 4- INS POLY W/PIN 12KV CLMP #4-653 ACSR

2

GPS: 33.330977, -118.318322

1492567E

70'

Class C2

RM: 1- POLE 70' CLASS 2 WOOD FULL TREAT
RM: 4- INS GLASS/POLY 35KV & LESS

1

RM

1492570E
60 1967
CL-2
1492569E
65 1967
CL-2

1492568E
60 1967
CL-2
1492567E
65 1967
CL-2

1492566E
80 1967
CL-2
1492565E
80 1967
CL-2

46073
75 20
CL-1
14925
60 20
CL-H1

MINE

RD

FIRE BREAK

RD

PAVELED