

SCE Aircraft Operations Flight Request Form

Instructions: Please complete this form in its entirety and email to: airops@sce.com or fax to 909-974-4678. Once this form is received by Aircraft Operations, you will receive a response within 24 hours. For questions call SCE Aircraft Operations Dispatch at PAX 11676.

Requestor Information

Flight requested by:*	
Department:*	
Pax:*	
Cell Number:*	
Email Address:*	

SAP Accounting Number*	
-------------------------------	--

Flight Description

Please choose a mission type:

- | | | |
|---|--------------------------------------|---|
| ☐ Camera – HD/IR | ☐ Line String | ☐ Pole-set |
| ☐ Crew support | ☐ Passenger | ☐ Recon |
| ☐ External Load | ☐ Patrol | ☐ Training |
| ☐ HEC | ☐ Photo | ☐ Need more info, please contact |

Mission specific details (ex: Passenger name, pole size/weight, external load type, etc):

General Operating Location	
District	
LZ Coordinates (if known)	
Pick-up location for passenger flights	
Drop-off location for passenger flights	

Date(s) for which service is requested	
Time of Pick-up	
Approx. mission duration (if known)	
Back-up date for mission (if known)	

Authorizer	
Authorizer PAX and cell number	

**required information*

For office use only

Date Received by Aircraft Operations: _____ Date Initial Contact Made: _____

Referred to contractor: ☐ No ☐ Yes, Date: _____ Company: _____

Follow up status: ☐ Week 1 _____

☐ Week 2 _____

☐ Week 3 _____

* NOTES:
HIGH FIRE - TIER 3
EAGLE ZONE
ENVIRO POLE - OPEN SPACE
BULLETIN 322 AREA
E-ALL POLE
COMPOSITE POLE
HARD ACCESS: IN THE MIDDLE OF AN OPEN FIELD
TR: 3/C 1/0A-16KV @ 37'6"

SECTIONAL COMPOSITE



N: 34° 27' 31.04"
W: 119° 51' 9.12"
ELEVATION: 179'
SET 1' NORTHWEST

- 11

RM

1996046E

40'

Class C5

RM: 1- POLE 40' CLASS 5 WOOD FULL TREAT

RM: 1- XA SNGL FB 10' STEEL PINS

RM: 3- INS GLASS & PIN 16KV

RM: 1- AG DOWN GUY 9/32" - 50' LESS THAN 22.5KV
- 12

POLE

1996046E

45'

Class C1

IN: 1- POLE 45' CLASS 1 RS COMP SEC POLE


IN: 1- XA SNGL TAN HD COMP 10' W/BKT @37'6"

IN: 3- INS POLY W/PIN 16KV CLMP #4-653 ACSR "ANGLE"

IN: 1- AG DOWN GUY 9/32" - 50' LESS THAN 22.5KV @ 37'

IN: 1- MISC AVIAN HOOD FOR HENDRIX INSUL #4-653

IN: 1- OH GUYING TEE W/HARDWARE CMP & WOOD



NOT TO SCALE

PROJECT REQUIREMENTS (Y/N)	
EDISON EASEMENT REQUIRED	☐
PWRD 88 REQUIRED	☐
UG CIVIL ONLY WORK ORDER	☐
PERMIT REQUIRED	☒
PERMIT TYPE: _____	
OUTAGE REQUIRED	☐
OUTAGE DATE: _____ TIME: _____	
TRAFFIC CONTROL REQUIRED	☐
PED. TRAFFIC CONTROL REQ'D	☐
CONVEYANCE LETTER REQ'D	☐
ENVIRONMENTAL CLEARANCE REQ'D	☒
CSD 140 (TLM) REQ'D	☐

DISTRICT 49 - SANTA BARBARA		PROJ. MGR. TOLMASOFF, LAURA PHONE 714-796-9811		PLANNER HAMPTON TEDDER PHONE 909-628-1253		DESIGNER HAMPTON TEDDER	
PROJECT NO. 1676498	SERVICE REQUEST 2583343	MSR NO.	PRODUCT-1 1464996-INFRA REPLAC - DET POLE REPLACEMENT		ASSOC DESGN		
CIRCUIT / VOLTAGE TRUMP 16KV		THOMAS GUIDE	PRODUCT-2		ASSOC DESGN		
SUB / PG NO. GOLETA		CIRCUIT CODE 18233	PRODUCT-3		ASSOC DESGN		
INVENTORY MAP 19-49		J.P.A. NO.		PROPOSED CONSTRUCTION (LOCATION) DETERIORATED POLE 1996046E LA PATERA CANYON RD 1168' N, 5268' W/O FRANKLIN RANCH RD GOLETA, CA			
TYPE	DATE	APPROVED BY	CHECKED BY	DRAWN BY	PAX #	SHEET 1 OF 1	
Southern California Edison Company						DESIGN\DRWG NO. 1085883_0.01	



1996046E

