



An *EDISON INTERNATIONAL*® Company

SCE Aircraft Operations Flight Request Form

Instructions: Please complete this form in its entirety and email to: airops@sce.com or fax to 909-974-4678. Once this form is received by Aircraft Operations, you will receive a response within 24 hours. For questions call SCE Aircraft Operations Dispatch at PAX 11676.

Requestor Information

Flight requested by:*	
Department:*	
Pax:*	
Cell Number:*	
Email Address:*	

SAP Accounting Number*	
-------------------------------	--

Flight Description

Please choose a mission type:

- | | | | | | |
|--------------------------|-----------------------|--------------------------|--------------------|--------------------------|---------------------------------------|
| ☐ | Camera – HD/IR | ☐ | Line String | ☐ | Pole-set |
| ☐ | Crew support | ☐ | Passenger | ☐ | Recon |
| ☐ | External Load | ☐ | Patrol | ☐ | Training |
| ☐ | HEC | ☐ | Photo | ☐ | Need more info, please contact |

Mission specific details (ex: Passenger name, pole size/weight, external load type, etc):

General Operating Location	
District	
LZ Coordinates (if known)	
Pick-up location for passenger flights	
Drop-off location for passenger flights	

Date(s) for which service is requested	
Time of Pick-up	
Approx. mission duration (if known)	
Back-up date for mission (if known)	

Authorizer	
Authorizer PAX and cell number	

**required information*

For office use only

Date Received by Aircraft Operations: _____ Date Initial Contact Made: _____

Referred to contractor: ☐ No ☐ Yes, Date: _____ Company: _____


Follow up status: ☐ Week 1

□ Week 2

☐ Week 3

HIGH FIRE - TIER 3
EAGLE ZONE
ENVIRO POLE - OPEN SPACE
BULLETIN 322 AREA
E-ALL POLE
COMPOSITE POLE
HARD ACCESS: ON THE SIDE OF A STEEP HILL
TR: 3/C 4B-16KV @ 37'6"

1	RM	74601E
	45'	Class C4
	RM: 1- POLE 45' CLASS 4 WOOD FULL TREAT	
	RM: 1- XA SNGL FB 10' STEEL PINS	
	RM: 3- INS POLY W/PIN 16KV CLMP #6-4/0 CU	
	RM: 1- AG DOWN GUY 9/32" - 50' LESS THAN 22.5KV	
2	POLE	74601E
	45'	Class C1
	IN: 1- POLE 45' CLASS 1 RS COMP SEC POLE	
	IN: 1- XA SNGL TAN HD COMP 10' W/BKT @ 37'6"	
	IN: 3- INS POLY W/PIN 16KV CLMP #6-4/0 CU "ANGLE"	
	IN: 1- MISC AVIAN HOOD FOR HENDRIX INSUL #4-653	
	IN: 1- AG DOWN GUY 9/32" - 50' LESS THAN 22.5KV	
	IN: 1- OH GUYING TEE W/HARDWARE CMP & WOOD	



PROJECT REQUIREMENTS (Y/N)	
EDISON EASEMENT REQUIRED	☐
PWRD 88 REQUIRED	☐
UG CIVIL ONLY WORK ORDER	☐
PERMIT REQUIRED	☐
PERMIT TYPE: _____	
OUTAGE REQUIRED	☐
OUTAGE DATE: _____ TIME: _____	
TRAFFIC CONTROL REQUIRED	☐
PED. TRAFFIC CONTROL REQ'D	☐
CONVEYANCE LETTER REQ'D	☐
ENVIRONMENTAL CLEARANCE REQ'D	☐
CSD 140 (TLM) REQ'D	☐

DISTRICT 49 - SANTA BARBARA		PROJ. MGR. TOLMASOFF, LAURA PHONE 714-796-9811		PLANNER HAMPTON TEDDER PHONE 909-628-1253		DESIGNER HAMPTON TEDDER	
PROJECT NO. 1676498		SERVICE REQUEST 2583343		MSR NO.		PRODUCT-1 1464996-INFRA REPLAC - DET POLE REPLACEMENT	
CIRCUIT / VOLTAGE TRUMP 16KV		THOMAS GUIDE		PRODUCT-2		ASSOC DESGN	
SUB / PG NO. GOLETA		CIRCUIT CODE 18233		PRODUCT-3		ASSOC DESGN	
INVENTORY MAP 19-49		J.P.A. NO.		PROPOSED CONSTRUCTION (LOCATION) DETERIORATED POLE 674601E CATHEDRAL OAKS RD 6711 N, 6170 E/O GLEN ANNIE RD GOLETA, CA			
2/19		JD/HTE					
TYPE	DATE	APPROVED BY	CHECKED BY	DRAWN BY	PAX #	SHEET 1 OF 1	DESIGN\DRWG NO. 1085883 0.01
Southern California Edison Company							



674601E

