

SCE Aircraft Operations Flight Request Form

Instructions: Please complete this form in its entirety and email to: airops@sce.com or fax to 909-974-4678. Once this form is received by Aircraft Operations, you will receive a response within 24 hours. For questions call SCE Aircraft Operations Dispatch at PAX 11676.

Requestor Information

Flight requested by:*	
Department:*	
Pax:*	
Cell Number:*	
Email Address:*	

SAP Accounting Number*	
-------------------------------	--

Flight Description

Please choose a mission type:

- | | | |
|---|--------------------------------------|---|
| ☐ Camera – HD/IR | ☐ Line String | ☐ Pole-set |
| ☐ Crew support | ☐ Passenger | ☐ Recon |
| ☐ External Load | ☐ Patrol | ☐ Training |
| ☐ HEC | ☐ Photo | ☐ Need more info, please contact |

Mission specific details (ex: Passenger name, pole size/weight, external load type, etc):

General Operating Location	
District	
LZ Coordinates (if known)	
Pick-up location for passenger flights	
Drop-off location for passenger flights	

Date(s) for which service is requested	
Time of Pick-up	
Approx. mission duration (if known)	
Back-up date for mission (if known)	

Authorizer	
Authorizer PAX and cell number	

**required information*

For office use only

Date Received by Aircraft Operations: _____ Date Initial Contact Made: _____

Referred to contractor: ☐ No ☐ Yes, Date: _____ Company: _____


Follow up status: ☐ Week 1 _____

☐ Week 2 _____

☐ Week 3 _____

NOTES:
-SCE TO PTD.
-HARD SET WEST.
-JOINT MEET REQ'D.
-HAND SET/DIG REQ'D.
-TRAFFIC CONTROL REQ'D.
-TREE TRIMMING REQ'D.
-EAGLE ZONE.
-BULL. 322 AREA.

TRANSFER:
2- #4 BC 16KV



RM 661390E 1
40'
Class C5
RM: 1- RM POLE 40' CLASS 5 WOOD FULL TREAT
RM: 1- XA DBLE FB 10' STEEL PINS
RM: 4- INS GLASS & PIN 16KV
RM: 1- AG DOWN GUY 3/8" - 50' LESS THAN 22.5KV

POLE 661390E 2
45'
Class C1
N: 34° 32' 23"
W: -119° 50' 53"
ELEVATION: 915'
IN: 1- POLE 45' CLASS 1 COMP SEC POLE
IN: 1- XA DBL HD TAN COMP 10'
IN: 4- INS POLY W/PIN 16KV CLMP #6-4/0 CU
IN: 1- OH GUYING TEE W/HARDWARE CMP & WOOD
IN: 1- AG DOWN GUY 3/8" - 50' LESS THAN 22.5KV



NOT TO SCALE

PROJECT REQUIREMENTS (Y/N)

EDISON EASEMENT REQUIRED ☐
PWRD 88 REQUIRED ☐
UG CIVL ONLY WORK ORDER ☐
PERMIT REQUIRED ☒
PERMIT TYPE: _____
OUTAGE REQUIRED ☐
OUTAGE DATE: _____ TIME: _____
TRAFFIC CONTROL REQUIRED ☒
PED. TRAFFIC CONTROL REQ'D ☐
CONVEYANCE LETTER REQ'D ☐
ENVIRONMENTAL CLEARANCE REQ'D ☒
CSD 140 (TLM) REQ'D ☐

DISTRICT 49 - SANTA BARBARA			PROJ. MGR. TOLMASOFF, LAURA M PHONE 714-796-9811			PLANNER TIDWELL DESIGN PHONE 805-647-4707			DESIGNER TIDWELL DESIGN			
PROJECT NO. 1710699		SERVICE REQUEST 2616883		MSR NO.		PRODUCT-1 1490858-INFRA REPLAC - DET POLE REPLACEMENT						ASSOC DESGN
CIRCUIT / VOLTAGE CACHUMA 16KV				THOMAS GUIDE N/A		PRODUCT-2						ASSOC DESGN
SUB / PG NO. VEGAS				CIRCUIT CODE		PRODUCT-3						ASSOC DESGN
INVENTORY MAP 29-50			J.P.A. NO. E6049-409901262			PROPOSED CONSTRUCTION (LOCATION) 661390E 5050 PARADISE RD., GOLETA						
						</						



661390E