



Requestor Information

Flight requested by:*	
Department:*	
Pax:*	
Cell Number:*	
Email Address:*	

SAP Accounting Number*	
-------------------------------	--

General Operating Location	
District	
LZ Coordinates (if known)	
Pick-up location for passenger flights	
Drop-off location for passenger flights	

Date(s) for which service is requested	
Time of Pick-up	
Approx. mission duration (if known)	
Back-up date for mission (if known)	

Authorizer	
Authorizer PAX and cell number	

□ Week 3


BREAST BLOCK & POLE KEY CALCS

1-1/0AT SLACK

1309 x .25 = 327.25

327.25 x 28.5 = 9,326.63 FT.LBS

35' DF CL5 BLB GRA = 10,878 FT.LBS



442
542

NOTES:

- SCE TO PTD.
- HARD SET WEST.
- JOINT MEET REQ'D.
- EAGLE ZONE.
- FEDERAL LAND (U.S. FOREST SERVICE).
- RIGHTS CHECK REQ'D.
- TREE TRIM REQ'D.
- BULLETIN 322 AREA.

TRANSFER:

- 1-1/0AT 120/240V SEC (SLACK)
- 2-#4AT 120/240V SVC

GPS COORDINATES

N: 34° 32' 30.10"

W: 119° 47' 09.82"

ELEVATION: 1110'

3

RM

35'

1346122E

Class C5

RM: 1- POLE RM 35' CLASS 5 WOOD FULL TREAT
RM: 2- SEC ROLLER (166-CLEVIS & SPOOL)

4

POLE

35'

1346122E

Class C5

IN: 1- POLE 35' CLASS 5 WOOD FULL TREAT
IN: 2- SEC ROLLER (166-CLEVIS & SPOOL)
IN: 1- AG BLOCK & POLE KEY

DISTRICT 49 - SANTA BARBARA		PROJ. MGR. TOLMASOFF, LAURA M PHONE 714-796-9811		PLANNER TIDWELL DESIGN PHONE 805-647-4707		DESIGNER TIDWELL DESIGN	
PROJECT NO. 1678149	SERVICE REQUEST 2584975	MSR NO.	PRODUCT-1 1466034-INFRA REPLAC - DET POLE REPLACEMENT		ASSOC DESGN		
CIRCUIT / VOLTAGE CACHUMA 16KV		THOMAS GUIDE N/A	PRODUCT-2		ASSOC DESGN		
SUB / PG NO. VEGAS		CIRCUIT CODE	PRODUCT-3		ASSOC DESGN		
INVENTORY MAP 29-53A		J.P.A. NO. E6049-409881191		PROPOSED CONSTRUCTION (LOCATION) 1346122E 150' W/O EL GAUCHO LN, 226' N/O PARADISE RD. SANTA BARBARA			
TYPE	DATE	APPROVED BY	CHECKED BY	DRAWN BY	PAX #	SHEET	
Southern California Edison Company						DESIGN/DRWG NO. 1086750_0.01	

1346122E



Dist.49 Deteriorated Pole
L / E