

SCE Aircraft Operations Flight Request Form

Instructions: Please complete this form in its entirety and email to: airops@sce.com or fax to 909-974-4678. Once this form is received by Aircraft Operations, you will receive a response within 24 hours. For questions call SCE Aircraft Operations Dispatch at PAX 11676.

Requestor Information

Flight requested by:*	
Department:*	
Pax:*	
Cell Number:*	
Email Address:*	

SAP Accounting Number*	
-------------------------------	--

Flight Description

Please choose a mission type:

- | | | |
|---|--------------------------------------|---|
| ☐ Camera – HD/IR | ☐ Line String | ☐ Pole-set |
| ☐ Crew support | ☐ Passenger | ☐ Recon |
| ☐ External Load | ☐ Patrol | ☐ Training |
| ☐ HEC | ☐ Photo | ☐ Need more info, please contact |

Mission specific details (ex: Passenger name, pole size/weight, external load type, etc):

General Operating Location	
District	
LZ Coordinates (if known)	
Pick-up location for passenger flights	
Drop-off location for passenger flights	

Date(s) for which service is requested	
Time of Pick-up	
Approx. mission duration (if known)	
Back-up date for mission (if known)	

Authorizer	
Authorizer PAX and cell number	

**required information*

For office use only

Date Received by Aircraft Operations: _____ Date Initial Contact Made: _____

Referred to contractor: ☐ No ☐ Yes, Date: _____ Company: _____

Follow up status: ☐ Week 1 _____

☐ Week 2 _____

☐ Week 3 _____

- SCE TO PTD.
- HARD SET NORTH WEST.
- JOINT MEET REQ'D.
- TREE TRIMMING REQ'D.
- RIGHTS CHECK REQ'D; U.S.F.S.
- HAND DIG REQ'D.
- HELICOPTER SET REQ'D.
- TRUCK ACCESS WITH MAJOR GRUBBING/GRADING/
& BRUSH CLEARANCE.
- EAGLE ZONE.
- BULL. 322 AREA.

3- #6 BC 16KV
1- 25KVA OPEN DELTA BANK
1- 15KVA 16KV 120/240V (1997)
1- 10KVA 16KV 120/240V (1997)
3- #2 WAL 120/240V SEC
1- #4 AQ 120/240V SEC SLACK

1- #4 AQ = 575LBS
575LBS x 25% x 32' = 4,608LBS
DF-TB 45' CLASS 4 GRADE A 8LBS = 17,138LBS

	SIZE	KVA	CUST	% LOAD
EXIST.	<u>25</u>	<u>17.7</u>	<u>4</u>	<u>70.8</u> %
PROP.	<u>25</u>	<u>17.7</u>	<u>4</u>	<u>70.8</u> %

PRI. CIRCUIT: CACHUMA 16KV

45' Class 02

IN: 1- POLE 45' CLASS 2 WOOD FULL TREAT

IN: 1- XA DBLE FB 10' STEEL PINS

IN: 3- INS POLY DE 16KV RIG #6

IN: 3- INS POLY W/PIN 16KV CLMP #6-4/0 CU

IN: 3- FE CO FAULT TAMER 20A 16KV 1-EA

IN: 2- MISC AVIAN TRANS BUSHING COVER 3.25-4.25

IN: 1- GR OH #6 SOL WP SECONDARY W/ROD

IN: 1- SEC 3-WIRE (284 RACK)

IN: 1- SEC ROLLER (166-CLEVIS & SPOOL)


IN: 1- AG ANCHOR ROD 1 " X 10' 3-EYE W/PLATE

IN: 2- AG DOWN GUY 9/32" - 50' LESS THAN 22.5KV

IN: 1- AG BLOCK & POLE KEY

IN: 3- FE FUSE TAMER 27KV 3A

45'	Class C4
RM: 1-	RM POLE 45' CLASS 4 WOOD FULL TREAT
RM: 1-	XA DBLE FB 10' STEEL PINS
RM: 3-	INS GLASS/POLY 35KV & LESS
RM: 3-	FE FH SMD20 17" 200A 16KV 1-EA
RM: 2-	MISC AVIAN TRANS BUSHING COVER 3.25-4.25
RM: 1-	GR OH #6 SOL WP SECONDARY W/ROD
RM: 2-	SEC 3-WIRE (284 RACK)
RM: 1-	AG DOWN GUY 9/32" - 50' LESS THAN 22.5KV
RM: 1-	AG ANCHOR ROD 3/4" X 8' 2-EYE W/PLATE



PROJECT REQUIREMENTS (Y/N)		DISTRICT 49 - SANTA BARBARA		PROJ. MGR. PARK, JU YOUNG PHONE 909-222-9350		PLANNER TIDWELL DESIGN PHONE 805-647-4707		DESIGNER TIDWELL DESIGN	
EDISON EASEMENT REQUIRED	☐	PROJECT NO. 1597752		SERVICE REQUEST 2506870		MSR NO.		PRODUCT-1 1401433-INFRASTRUCTURE REPLACEMENT PLP	
PIRD 88 REQUIRED	☐	CIRCUIT / VOLTAGE CACHUMA 16KV		THOMAS GUIDE N/A		PRODUCT-2		ASSOC DESIGN	
UG CIVIL ONLY WORK ORDER	☐	SUB / PG NO. VEGAS		CIRCUIT CODE		PRODUCT-3		ASSOC DESIGN	
PERMIT REQUIRED	☒	INVENTORY MAP 29-52A		J.P.A. NO. E6049-409330902		PROPOSED CONSTRUCTION (LOCATION) 903417E			
PERMIT TYPE: USFS						16 PARADISE RD., SANTA BARBARA			
OUTAGE REQUIRED	☒								
OUTAGE DATE: _____ TIME: _____									
TRAFFIC CONTROL REQUIRED	☐								
PED. TRAFFIC CONTROL REQ'D	☐								
CONVEYANCE LETTER REQ'D	☐								
ENVIRONMENTAL CLEARANCE REQ'D	☒			TIDWELL					
CSD 140 (TLM) REQ'D	☐								
		TYPE	DATE	APPROVED BY	CHECKED BY	DRAWN BY	PAX #	SHEET	DESIGN\DRWG NO.
		Southern California Edison Company					OF	1035844	0.01

D124; Rev. 02/08/18

90347E

L/W

05/09/2018