


FILE NAME: 1696789_0.01.0WG SAVE DATE: 4/10/2024 10:33 AM SAVED BY: THOMPSON

CIRCUIT 1 = REVERSE PEAK 12KV % JUNE LAKE SUB
CIRCUIT 2 = GULL LAKE 12KV % JUNE LAKE SUB
CIRCUIT 3 = AGNEW 4KV % RUSH CREEK SUB

The graph shows a sharp increase in project value for 'PM: 10 B' compared to 'PM: 10 A'. The x-axis is labeled 'PROJECT LOCATION' and the y-axis is labeled 'PROJECT VALUE'.

FINAL DESIGN
APPROVED FOR CONSTRUCTION

UNDERGROUND SERVICE ALERT
Contact USA
Dial 811 or 800-422-4133
www.digalert.org/contact

For Underground Locating
 Two Working Days Before You Dig

CIRCUIT 1 = REVERSE PEAK 12KV % JUNE LAKE SUB
CIRCUIT 2 = GULL LAKE 12KV % JUNE LAKE SUB
CIRCUIT 3 = AGNEW 4KV % RUSH CREEK SUB

AREA SUBJECT TO DISPATCHERS BULLETIN NO. 322

WHEN A RED FLAG WARNING IS IN EFFECT, THE LINE OR LINE SECTION WILL NOT BE RE-ENERGIZED FOLLOWING A LOCKOUT UNTIL THE LINE OR LINE SECTION, SUBJECT TO BULLETIN 322 RESTRICTION, HAS BEEN COMPLETELY PATROLLED BETWEEN THE SOURCE STATION OR STATIONS AND THE FAULT.

FINAL DESIGN
APPROVED FOR CONSTRUCTION

DATE	REVISION DESCRIPTION	APPROVED	DRAWN	CHECKED								
	PROJECT NO. 85 - BISHOP	SERVICE REQUEST 2377354 - 3268279			MSR NO.	SANDOVAL, JULIE L. PHONE 6266078611		PLANNER	THOMPSON, L. GERALD LEON PHONE 951-691-0861		ORIG.CO.	MAYRA
	CIRCUIT VOLTAGE REVERSE PEAK 12KV				GPS	VARIOUS		PRODUCT-1	2220084-GRID RESILIENCY			ASSOC DESIGN
	SUB / PG NO. JUNE LAKE				ORIG CODE	1492B		PRODUCT-2	1967124-GRID RESILIENCY			ASSOC DESIGN
	INVENTORY MAP SEE ABOVE	J.P.A. NO.			PROPOSED CONSTRUCTION (LOCATION)			2024 PIF#385026 - 4PA GR CC - REVERSE PEAK 12KV				
					VARIOUS LOCATIONS			BISHOP, CA 93514				
	B 05/05/22	K5/U05 / AR	SVG/U05	30276								
TYPE	DATE	APPROVED BY	CHECKED BY	DRAWN BY	PAX #	SHEET	DESIGN/DWG NO.		1B OF 4 1696789_0.01			
Southern California Edison Company												

UNDERGROUND SERVICE ALERT
Contact USA
Dial 811 or 800-422-4133
www.digalert.org/contact

For Underground Locating
 Two Working Days Before You Dig

NOTES: (1930142E)

- NO TRUCK ACCESS; POLE IS LOCATED IN INYO NATIONAL FOREST
- HELI-SET W/ SONO-TUBE
- REPLACE POLE DUE TO SPLITTING
- E-PTD
- SET 1' EAST
- ANGLE 36°
- TREE TRIMMING

HELICOPTER SET

	T02220084	EXTREME POLE
32	RM: 1930142E	
	40'	CLASS 5
	RM: 1 - POLE 40' CLASS 5 WOOD FULL TREAT	
	RM: 1 - XA SNGL BV 8' STEEL PINS	
	RM: 390' - CD 1/0 STR AL BARE ACSR NON-GREASED	
	3 - INS GLASS/POLY 35KV & LESS	
	RM: 1 - AG DOWN GUY 9/32" - 50' LESS THAN 22.5KV (⊙ 32')	
	RM: 1 - AG ANCHOR ROD 3/4" X 8' 2-EYE W/PLATE (L = 21')	
	T02220084	EXTREME POLE
33	IN: 1930142E	
	45'	CLASS 1
	IN: 1 - POLE 45' CL 1 CMP SEC POLE W 18" SHLD	
	IN: 1 - XA DBL HD TAN COMP 10'	
	IN: 390' - 1/0 ATW XLHPOE INS CABLE 17KV	
	6 - POST INSULATOR ANGLE BRACKET	
	IN: 1 - V-BRACE KIT TNG 10' CMP DBL ARM V-BRACE	
	IN: 6 - INS 15KV POLY POST TRUN #4-336 SHD STD	
	IN: 1 - AG DOWN GUY 3/8"-50' W/2-FGSI ALL KV (⊙ 36')	
	IN: 1 - AG 17' PLT W/ 1'X10' 3 EYE ROD (L = 21')	

TD2220084	EXTREME	35
IN: 1930143E	POLE	
45'	CLASS 1	
IN: 1 - POLE 45' CL 1 CMP SEC POLE W 18' SHLD		
IN: 1 - XA DBL HD TAN COMP 10'		
IN: 360' - 1/0 ATW XLHDE INS CABLE 17kv		
IN: 1 - V-POLE KIT TNG 10' CMP DBL ARM V-BRACE		
IN: 6 - INS 15KCV POLY POST TRUN #4-336 LG STD		

TD2220084	*HELICOPTER SET*	
RM: 1930144E	POLE	36
40'	CLASS 5	
RM: 1 - POLE 40' CLASS 5 WOOD FULL TREAT		
RM: 2 - XA DBLE VY 10" STEEL PINS		
RM: 495' - CD 1/0 SIR AL BARE ACSN NON-GREASED		
RM: 7 - INS GLASS/PLYL 35KV & LESS		
RM: 1 - AG DOWN GUY 3/8" - 50' LESS THAN 22.5KV (Ø 28")		
RM: 1 - AG DOWN GUY 3/8" - 50' LESS THAN 22.5KV (Ø 32")		
RM: 1 - AG DOWN GUY 3/8" - 50' LESS THAN 22.5KV (Ø 29")		
RM: 1 - AG ANCHOR ROD 3/4" x 8' 2-EYE W/PLATE (L = 30")		
RM: 1 - AG ANCHOR ROD 3/4" x 8' 2-EYE W/PLATE (L = 30")		
RM: 1 - AG ANCHOR ROD 3/4" x 8' 2-EYE W/PLATE (L = 28")		

TD2220084	EXTREME
IN: 1930144E	POLE
45'	CLASS 1
IN: 1 - POLE 45' CL 1 CMP SEC POLE W 18" SHLD	(37)
IN: 2 - XA DBL DR OF COVER 10' W	
IN: 495' - 1/0 ATW XLHDPD INS CABLE 17kV	
IN: 6 - INS POLY DE 12KV HVY LOAD #4 & 1/0	
IN: 6 - MISC OH CC AVAIL DE COVER W/DL EXTENSION	
IN: 2 - V-BRACE KIT DE 10" CMP DBL ARM V-BRACE	
IN: 6 - INS 15KV POLY POST TRUN #4-336 LG STD	
IN: 1 - AG DOWN GUY 3/8"-50' W/2-FGSI ALL KV (Ø 36 9")	
IN: 1 - AG DOWN GUY 3/8"-50' W/2-FGSI ALL KV (Ø 37)	
IN: 1 - AG DOWN GUY 3/8"-50' W/2-FGSI ALL KV (Ø 32)	
IN: 1 - AG 17" PLT W/ 1'X10' 3 EYE ROD (L = 28")	
IN: 1 - AG 17" PLT W/ 1'X10' 3 EYE ROD (L = 31")	
IN: 1 - AG 17" PLT W/ 1'X10' 3 EYE ROD (L = 30")	

NOTES: (1930144E)

- NO TRUCK ACCESS; POLE IS LOCATED IN INYO NATIONAL FOREST
- HELI-SET W/ SONO-TUBE
- REPLACE POLE DUE TO SPLITTING
- E-PTD
- SET 1' NORTHWEST
- TREE TRIMMING



FINAL DESIGN
APPROVED FOR CONSTRUCTION

GRID MAP NO.'S

LB-1282-H	LB-1482-
LB-1382-G	LB-1481-
LB-1382-H	LB-1482-
LB-1381-B	LB-1482-
	LB-1582-

DISTRICT		PROJ. NAME: SANDOVAL, JULIE L		PLANNER		THOMPSON, J. GERALD LEON DESIGNER	
B5 BISHOP		P.O. # 626607661		909-491-0661		CARROZO, MAYRA	
PROJECT NO.		SERVICE REQUEST		MSR NO.		PRODUCT	
2377354		3268279				2220084-GRID RESILIENCY	
CIRCUIT / VOLTAGE		CIRCUIT		QPS		PRODUCT	
REVERSE PEAK 12KV		VARIOUS		VARIOUS		196727-GRID RESILIENCY	
SUB / PG. NO.		CIRCUIT CODE		PRODUCT-3		2220082-GRID RESILIENCY	
JUNE LAKE		14926					
INVENTORY MAP		SEE ABOVE		I.P.A. NO.		PROPOSED CONSTRUCTION (LOCATION)	
						2024 PF385026 - 4PA GR CC - REVERSE PEAK 12KV	
						VARIOUS LOCATIONS	
						BISHOP, CA 93514	
B 05/05/22		APPROVED BY		KS/ABS / AR		SWS/ABS 30276	
TYPE		DATE		CHECKED BY		DRAWN BY	
						PAX	
Southern California Edison Company SHEET 4 OF 4							
						DESIGN/DRWG NO. 1696789_0.01	

For Underground Locating Two Working Days Before You Dig